



#### NOTES:

1. CONSUMER CONDUCTOR TAILS MUST BE A MINIMUM OF 24" IN LENGTH IN ORDER TO FORM DRIP LOOP
2. GUY & ANCHOR TO BE INSTALLED ON ALL SERVICES GREATER THAN 75' OR ON SERVICES LESS THAN 75' AS DETERMINED BY THE COOPERATIVE
3. GUY & ANCHOR TO BE POSITIONED IN-LINE BUT OPPOSITE OF THE PULL OF THE SERVICE WIRE
4. U-BOLT CLAMPS OR APPROVED CONNECTORS MUST BE USED ON GUY WIRE
5. NO MORE THAN 6" OF THE THIMBLE EYE AND ANCHOR ROD ABOVE GRADE
6. 8' WHITE OR YELLOW PLASTIC MARKER ATTACHED TO GUY IF EXPOSED TO TRAFFIC
7. IF SERVING A MOBILE HOME, NEC REQUIRES THAT THE SERVICE POLE BE NO MORE THAN 30' FROM THE EXTERIOR WALL OF THE MOBILE HOME
8. NESC REQUIRES ALL METER POLES TO BE NO CLOSER THAN 5' TO ANY BUILDING OR STRUCTURE
9. ITEMS MARKED WITH AN ASTERISK (\*) ARE TO BE INSTALLED BY THE CONSUMER / ELECTRICIAN
10. SPECIFICATIONS ON THIS PAGE REPRESENT MINIMUM STANDARDS. MORE STRINGENT REQUIREMENTS MAY BE DICTATED BY LOCAL CODES. INSTALLATIONS MUST CONFORM TO ALL APPLICABLE CODE REQUIREMENTS INCLUDING THE MOST RECENT EDITION OF THE NEC.
11. DRAWING NOT TO SCALE

**SATILLA REMC**

**METER POLE INSTALLATION**

**SATILLA REMC**

Dwg date :  
02/13/13

Effective date :  
02/13/13

**M25-5**